



**NOTES:**

1. BASE MATERIAL TO BE CRUSHED AGGREGATE BASE UNLESS OTHERWISE SPECIFIED.
2. STRAIGHT GRADE AT BOTTOM OF BASE.
3. WHERE BASE IS REQUIRED UNDER GUTTER, THICKNESS SHALL BE 4" MINIMUM.
4. CRUSHED AGGREGATE BASE OR SELECT SUBBASE WITH EXPANSION LESS THAN 3% BY SOIL TEST.
5. BASE REQUIREMENT TO BE DETERMINED BY SOIL ANALYSIS.

**CITY OF CARSON**

**BASE DETAILS FOR  
HIGHWAYS, STREETS & ALLEYS**

DRAWN BY  
*P. J. ...*  
DATE APPROVED

RECOMMENDED: *W. Hubel* APPROVED:  
DIVISION ENGINEER DIRECTOR OF PUBLIC WORKS

**NO. 104**