



LUMINAIRE AS MANUFACTURED BY GENERAL ELECTRIC CO. OR APPROVED EQUAL WITH RECEPTACLE FOR EXTERNAL MOUNTED PHOTOELECTRIC CELL * LUMINAIRE SHALL BE EQUAL TO GE#C724N806 W/#C402G600 PHOTOELECTRIC CELL & 250W HPS LAMP.

PACIFIC UNION METAL CO. "MARBELLITE" LIGHT STANDARD "G-31" SERIES OR APPROVED EQUAL

OPENING TO BE LOCATED AWAY FROM TRAFFIC FLOW

1/4" LAYER OF SAND TO BREAK BOND

CLASS 564-C-300LBS PORTLAND CEMENT CONCRETE

DESIGN STANDARD	POLE BASE PLATE (IN)				ANCHOR ROD SIZE "D"
	"B"	"F"	"S"	"T"	
G-31	12-1/2	8-7/8	13-1/2	1	1"X36"X4"

NO. 5 PULL BOX SHALL BE FURNISHED WITH:

1. 5/8" DIA. COPPER GROUND ROD, 8" LONG IN PULL BOX ADJACENT TO EDISON CO. SERVICE ONLY AND SHALL BE CONNECTED TO CIRCUIT BY A SEPARATE GREEN CODE NO. 8 WIRE AT THE SERVICE CAN.
2. TRON WATER-PROOF FUSE (8 AMP) HOLDER HEB-AA MCGRAW -EDISON CO. OR APPROVED EQUAL FOR 120 VOLT CIRCUITS.
3. A COVER INDICATING "STREETLIGHT".
4. ALL STREETLIGHT CONDUIT SHALL BE 1" DIA. GALVANIZED STEEL*

CITY OF CARSON

STREETLIGHT STANDARD AND INSTALLATION DETAIL

DRAWN BY *R. J. ...*
 DATE APPROVED 2/2/87

RECOMMENDED: *W. Heber* DIVISION ENGINEER
 APPROVED: *Harold C. Williams* DIRECTOR OF PUBLIC WORKS

NO. 500