



**SECTION**

**NOTES:**

1. TREE WELLS SHALL BE SPACED APPROXIMATELY FIFTY (50) FEET APART, BUT NOT LESS THAN ONE PER RESIDENTIAL LOT.
2. LOCATION OF TREE WELLS WILL BE SUBJECT TO THE FOLLOWING CONDITIONS:
  - A. 50' FROM THE BCR ON THE APPROACH TO AN INTERSECTION AND 15' FROM THE ECR ON THE EXIT SIDE.
  - B. 20' FROM LIGHT STANDARDS.
  - C. 10' FROM FIRE HYDRANTS AND DRIVEWAYS.
  - D. 5' FROM HOUSE WALKS AND UTILITY METERS.
3. TREE WELLS ARE TO BE BACKFILLED WITH CLEAN DIRT AND FLUSH WITH ADJACENT WALK UNTIL TREES ARE PLANTED.
4. WEAKENED PLANE JOINTS TO BE 20' ON CENTER.

**CITY OF CARSON**

**CASE 2  
FULL WIDTH SIDEWALK  
WITH TREE WELLS**

REVISIONS

RECOMMENDED: W. Huber APPROVED: Harold C. Williams  
 DIVISION ENGINEER DIRECTOR OF PUBLIC WORKS

DRAWN BY R. Parsons  
 DATE APPROVED 2/2/87  
**NO. 117**